

|  |  |                                |  |   |  |  |  |
|--|--|--------------------------------|--|---|--|--|--|
| <b>AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT</b>  |  |                                |  | 1. Contract Number  |  | Page of Pages<br>1 3                                 |  |
| 2. Amendment/Modification Number<br>DCCE-2007-B-0057-001   |  | 3. Effective Date<br>26-Mar-07 |  | 4. Requisition/Purchase Request No.                       |  | 5. Solicitation Caption<br>Re-Lamping at MLK Library |  |
| 6. Issued By:<br>Office of Contracting and Procurement<br>Construction Design and Building Renovation<br>441 4th Street, NW, Suite 700 South<br>Washington, DC 20001   |  |                                |  | 7. Administered By (If other than line 6)                 |  |  |  |
| 8. Name and Address of Contractor (No. Street, city, country, state and ZIP Code)  |  |                                |  | (X) 9A. Amendment of Solicitation No.<br>DCCE-2007-B-0057 |  |  |  |
|  |  |                                |  | 9B. Dated (See Item 11)<br>3/15/2007                      |  |  |  |
|  |  |                                |  | 10A. Modification of Contract/Order No.                   |  |  |  |
|  |  |                                |  | 10B. Dated (See Item 13)                                  |  |  |  |
| Code   |  | Facility                       |  |   |  |  |  |
| <b>11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS</b>   |  |                                |  |   |  |  |  |
| <input type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offers <input type="checkbox"/> is extended. <input checked="" type="checkbox"/> is not extended.<br>Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing Items 8 and 15, and returning <u>1</u> copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or fax which includes a reference to the solicitation and amendment number. <b>FAILURE OF YOUR ACKNOWLEDGEMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER.</b> If by virtue of this amendment you desire to change an offer already submitted, such change may be made by letter or fax, provided each letter or telegram makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified. |  |                                |  |   |  |  |  |
| 12. Accounting and Appropriation Data (If Required)  |  |                                |  |   |  |  |  |
| <b>13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS, IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14</b>   |  |                                |  |   |  |  |  |
| (X) A. This change order is issued pursuant to: (Specify Authority)<br>The changes set forth in Item 14 are made in the contract/order no. in item 10A.  |  |                                |  |   |  |  |  |
| B. The above numbered contract/order is modified to reflect the administrative changes (such as changes in paying office, appropriation date, etc.) set forth in item 14, pursuant to the authority of 27 DCMR, Chapter 36, Section 3601.2.  |  |                                |  |   |  |  |  |
| C. This supplemental agreement is entered into pursuant to authority of:   |  |                                |  |   |  |  |  |
| D. Other (Specify type of modification and authority)  |  |                                |  |   |  |  |  |
| <b>E. IMPORTANT:</b> Contractor <input type="checkbox"/> is not, <input checked="" type="checkbox"/> is required to sign this document and return <u>1</u> copies to the issuing office.   |  |                                |  |   |  |  |  |
| 14. Description of amendment/modification (Organized by UCF Section headings, including solicitation/contract subject matter where feasible.)  |  |                                |  |   |  |  |  |
| Solicitation No. DCCE-2007-B-0057 for the Re-Lamping at Martin Luther King Library is hereby amended as follows:   |  |                                |  |   |  |  |  |
| (1). Delete in its entirety and insert attached Section B.4 in its place.  |  |                                |  |   |  |  |  |
| (2). Specifications: Part 2 Products, Section 2.2 Luminaires , A.1, delete in its entirety and insert Voltage: 277-V ac in its place.  |  |                                |  |   |  |  |  |
| (3). Question: Is the area at the grid lines 1-3, D-K, 5-6, D-F, and 5-6, H-K included in the scope of work?<br>Answer: Grid Lines 1-3, D-K are included in the scope of work. Grid Lines 5-6, D-F and 5-6, H-K are not included in the scope of work.   |  |                                |  |   |  |  |  |
| (4). Question: What is the time of completion?<br>Answer: The period of performance is 60 days from the Notice to Proceed.   |  |                                |  |   |  |  |  |
| All other terms and conditions remain the same.  |  |                                |  |   |  |  |  |
| Except as provided herein, all terms and conditions of the document referenced in Item (9A or 10A) remain unchanged and in full force and effect   |  |                                |  |   |  |  |  |
| 15A. Name and Title of Signer (Type or print)  |  |                                |  | 16A. Name of Contracting Officer<br>(signed)              |  |  |  |
| 15B. Name of Contractor  |  | 15C. Date Signed               |  | 16B. District of Columbia<br>Geoffrey Mack                |  | 16C. Date Signed<br><br>3/27/2007                    |  |
| (Signature of person authorized to sign)   |  |                                |  | (Signature of Contracting Officer)                        |  |  |  |

**PART I****SECTION B: SCHEDULE FOR CONSTRUCTION, ALTERATIONS, REPAIRS PRICE**

**B.1** The District of Columbia Office of Contracting and Procurement (OCP), on behalf of the District of Columbia Public Libraries (DCPL) is seeking a Contractor to provide all labor, materials and equipment necessary to re-lamp, clean fixtures, clean ceiling tiles, paint ceiling tiles at the Martin Luther King Library at 901 G Street, NW, Washington, D.C., in accordance with the attached Scope, Specifications and Drawings.

**B.2** **DESIGNATION OF SOLICITATION FOR THE SMALL BUSINESS SET ASIDE MARKET ONLY:**

This Invitation for Bids is designated for certified small business enterprise (SBE) bidders only under the provisions of the "Small, Local, and Disadvantaged Business Enterprise Development and Assistance Act of 2005" (the Act), Title II, Subtitle N, of the "Fiscal Year 2006 Budget Support Act of 2005" as amended.

An SBE must be certified as small in the procurement category of Building Construction in order to be eligible to submit a bid in response to this solicitation.

**B.3** The District contemplates award of a firm fixed-price contract. The estimated price range for this requirement is between \$250,000.00 and \$500,000.00.

**B.4** The Contractor must bid lump sum firm fixed prices for the following Contract Line Item Number (CLIN) as described below.

| <b><u>CLIN No.</u></b> | <b><u>DESCRIPTION</u></b>               | <b><u>QTY</u></b> | <b><u>Unit Price</u></b> | <b><u>Firm Fixed Price</u></b> |
|------------------------|---|-------------------|--------------------------|--------------------------------|
| 0001                   | Remove and dispose existing Ballasts    | <u>1480 EA</u>    | \$ _____                 | \$ _____                       |
| 0002                   | Remove and dispose existing Bulbs       | <u>3100 EA</u>    | \$ _____                 | \$ _____                       |
| 0003                   | Remove and dispose non-working fixtures | <u>110 EA</u>     | \$ _____                 | \$ _____                       |
| 0004                   | Misc. removal and disposal              | <u>1 LS</u>       | \$ _____                 | \$ _____                       |
| 0005                   | Clean existing lenses                   | <u>1480 EA</u>    | \$ _____                 | \$ _____                       |
| 0006                   | Install new ballasts                    | <u>1480 EA</u>    | \$ _____                 | \$ _____                       |
| 0007                   | Install new T8 fluorescents Light bulbs | <u>2960 EA</u>    | \$ _____                 | \$ _____                       |

|      |  |                  |          |          |
|------|--|------------------|----------|----------|
| 0008 | Install new exterior "canister"<br>Fixtures  | <u>125</u> EA    | \$ _____ | \$ _____ |
| 0009 | Install new interior "canister"<br>Fixtures  | <u>11</u> EA     | \$ _____ | \$ _____ |
| 0010 | Painting of ceiling tiles  | <u>64,100</u> SF | \$ _____ | \$ _____ |
| 0011 | Cleaning of ceiling tiles  | <u>64,100</u> SF | \$ _____ | \$ _____ |
| 0012 | Install new ceiling light Exit<br>Signs  | <u>10</u> EA     | \$ _____ | \$ _____ |
| 0013 | Miscellaneous AWG copper<br>Wire   | <u>1000</u> LF   | \$ _____ | \$ _____ |
| 0014 | Miscellaneous Electrical<br>Improvements   | <u>1</u> LS      | \$ _____ | \$ _____ |
| 0015 | Lump Sum Total Bid Price<br>(0001+0002+0003+0004<br>+0005+0006+0007+0008<br>+0009+0010+0011+0012<br>+0013+0014=0015) |                  |          | \$ _____ |

**LUMP SUM PRICE IN WORDS**  
  

---